

**TYPGODKÄNNANDEBEVIS 0157****MED BESLUT OM TILLVERKNINGSKONTROLL**

SAKORD: AVLOPPSVATTEN

Brunnar mm i mark. Slamavskiljare

BBR 6:64

BSAB: PM

**SLAMAVSKILJARE SA 900****Innehavare**

FANN VA-teknik AB, Dackevägen 33, 117 34 Järfälla.

Tel. +46 (0)8-761 02 21. Fax +46 (0)8-761 46 70.

**Produkt**

Slamavskiljare utformad som en liggande rektangulär behållare utan invändiga mellanväggar. Avskiljarens arbetsöppning som kan förses med förhöjningsrör har nominell storlek DN 600 och är försedd med låsbart lock. Låsförsett lock uppfyller kraven enligt BBR 8:952. Produkten tillverkas genom rotationsgjutning av polyeten.

**Avsedd användning**

Rensning av spillvatten (BDT) från högst ett hushåll eller högst 5 personekvivalenter.

**Godkännande**

Produkten utförd och installerad enligt tillhörande handlingar godkänns med avseende på följande avsnitt i Boverkets Byggregler (BBR) och Boverkets konstruktionsregler (BKR):

Byggprodukter med bestyrkta egenskaper	BBR 1:4
Installationer för spillvatten	BBR 6:4
Utformning	BBR 6:644
Krav i brottgränstillstånd	BKR 2:11

För avsedd användning uppfyller produkten följande krav i 2§

Lag om tekniska egenskapskrav på byggnadsverk m.m. (BVL):

1. Bärförmåga, stadga och beständighet
3. Skydd med hänsyn till hygien, hälsa och miljö

**Giltighetstid**

Beslutsdatum 2011 04 28 Dnr 239/11. Typgodkännandet gäller t o m 2014 04 27.

Godkännandet förutsätter att innehavaren årligen rapporterar till Swedcert om utförd tillverkningskontroll.


Detta typgodkännandebevis ersätter tidigare bevis med samma nummer, daterat 2009 03 24, Dnr 095/09.

Vid leverans till byggplats skall produkten åtföljas av tillverkarförsäkran enligt BFS 2000:27, TYP 2.

SWEDCERT AB

Bilaga 1	Tillhörande handlingar	2011 04 28.
Bilaga 2	Produktmärkning	2011 04 28.
Bilaga 3	Kontrollanvisningar	2009 03 24.
Bilaga 4	Bedömningsunderlag	2011 04 28.

  
Bertil Wolgast  
VD

  
Magnus Jerlmark  
Tekniskt ansvarig

**SWEDCERT**

# TYPE APPROVAL CERTIFICATE 0157

## WITH REGULATIONS ON PRODUCTION CONTROL

KEYWORDS: WASTEWATER

BBR 6:64

Ground manholes etc. Sludge separator

BSAB: PM

### SLUDGE SEPARATOR SA 900

#### Certificate holder

FANN VA-teknik AB, Dackevägen 33, 117 34 Järfälla.  
Tel +46 (0)8-761 02 21. Fax +46 (0)8-761 46 70.

#### Product

Sludge separator in the form of a horizontal rectangular container with no interior partitions. The access opening, which can be fitted with a level adjustment pipe has a nominal size of DN 600 and has a lockable lid. Lids with locks meet the requirements according to BBR 8:952. The product is manufactured using rotary casting of polyethylene.

#### Application

Purification of foul water from max 1 household or the equivalent of max 5 persons.

#### Approval

The product, constructed and installed in accordance with the associated documents is approved with reference to the following paragraphs in the Swedish Building Code (BBR) and Swedish Construction Code (BKR):

Construction products with certified characteristics	BBR 1:4.
Waste water installations	BBR 6:64.
Design	BBR 6:644.
Requirements for maximum load	BKR 2:11.

Within the prescribed field of application the product meets the criteria stipulated in 2§ Regulations governing the technical properties of materials used in building construction etc. (BVL):

1. Bearing capacity, stability and durability.
3. Protection in terms of hygiene, health and environment.


#### Period of Validity


Type approval issued 28/4/2011. Registration number 239/11. Type approval valid until 27/4/2014. This certificate replaces the earlier certificate of the same number, dated 24/3/2009. Registration no.095/09. The type approval is granted on condition that the holder of the certificate reports annually to Swedcert on production control carried out.

On delivery to site a certificate issued by the manufacturer shall accompany the product, in accordance with BFS 2000:27, TYP 2.

SWEDCERT AB

Appendix 1 Associated Documents	28/4/2009.
Appendix 2 Product Markings	31/3/2004.
Appendix 3 Quality Control Documents	28/4/2011.
Appendix 4 Basis of Approval	28/3/2011.

  
Bertil Wolgast  
Managing Director

  
Magnus Järnmark  
Technical Manager



# SWEDCERT

