

[print](#) | [close](#)

detailed view of article 3078280  
for your search 3078280

name:

customer version	DMDE_en
production site	Ansbach
measuring principle	ultrasonic
nominal flow	0,6 m <sup>3</sup> /h
nominal diameter	15 mm
body length	110mm
connection	G3/4B
connection standard	DIN ISO 228-1
temperature	105 °C
nominal pressure	16 bar
approval	MID
metrological class volume	class 2 1:100
metrological class energy	dT 3-90 K
1st verification	conformity declared
installation position	any position
energy unit	MWh, 3 digits after comma
volume unit	m <sup>3</sup> , 3 digits after comma
interface module 1	Radio 868 Open Metering
transmission period	standard (walk-by)
application	heat meter
installation of flow sensor	return
radio key	OMS3_Schlüssel_DMDE
temperature sensor	Pt500 5,2mm PVC 1,5m
temp. sensor installation	return sensor temp.sensor installed brass screw
temp. sensor installation	forward sensormounting set M10*1 brass
drill for temperature sensor	5,6 mm
power supply	Batterie 2xAA-Zelle 3,6VDC soldered
product name	SHARKY
property number	
software	F03-003
radio telegram	customer specific
cable length (flow sensor - calculator)	0,5 m
log memory interval 0	month
log memory interval 1	1 day
log memory interval 2	month
M-Bus primary address type	customer number
accounting date 1	end of May
accounting date 2	end of december
integration time max. values	15 min
outer packaging	without
Wandhalterung	without
pps_grundtyp	GA774049
<b>release status</b>	<b>active</b>

[print](#) | [close](#)