

## Sudopress, press fittings for copper pipes

Holder/Issued to

### PEGLER YORKSHIRE GROUP LTD

ST CATHERINES AVENUE, DONCASTER DN4 8DF, England

Organisation number/VAT number: GB418913192

Phone: 01302 560560, Fax: +44 1302 560 203

Web: [www.pegleryorkshire.co.uk](http://www.pegleryorkshire.co.uk)

### Product description

Sudopress press fittings manufactured from copper (CW024A) are available in dimensions 12, 15, 18, 22, 28, 35, 42 and 54mm. Dimension 15, 18, 22 and 28mm is available in a version with press fittings made of copper (CW024A) with transition to threads in red brass (CC499K).

Fittings have o-rings that are designed to leak in unpressed condition. When joining pipe parts and pipes, it is assumed that pressing tools approved by the type-approval holder are used.

### Intended use

Press fittings intended for joining soft (R220), semi-hard (R250) and hard copper pipes (R290) with Dy 12-54 mm in tap water installation where the quality of the water can be compared with water from municipal facilities and at speeds that do not cause corrosion. When connecting soft copper tubes, copper support sleeves should always be used.

### Trade name

SudoPress fittings for copper pipe.

### Approval

The products satisfy the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

Tap water installations\*

6:62, 1:st sentence and 2:nd paragraph  
and general recommendation

Design

6:625, 1:st and 4:th paragraph

\*The products complies with Boverkets (the National Board of Housing, Building and Planning) updated threshold value for max. amount of dissolved lead as described in BBR 21, 2014-06-17.

### Associated documents

VSH SudoPress dated 2019-02-10

Type approval SC1013-16 | 2019-09-02

RISE Research Institutes of Sweden AB | Certification

Box 857, SE-501 15 Borås, Sweden

Phone: +46 10-516 50 00

certifiering@ri.se | [www.ri.se](http://www.ri.se)

2018-01-30



## Control

The factory production control (FPC) is monitored by an independent inspection body.  
Control agreement: 132. Inspection body: DTI Danish technological institute.

When the building proprietor performs inspection at the building, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this approval is based.

## Manufacturing places

Production control includes the following places:

Pegler Yorkshire SDH INDUSTRIE 46 Rue-de l'industrie 45550 SaintDenis-de-l'Hotel, France, 12-28mm  
YORKSHIRE FITTINGS Gyarto Kft MAGLODI UT 16- BUDAPEST, HUNGARY, 35-54mm

## Marking

The products are to be marked at the factory. The marking consists of a label or text on every product/packing supplied and includes:

Holder

Brand name

Product type designation

Consecutive manufacture date of production

Type approval number

Dimension

Boverket's registered trade mark

RISE Accreditation number

Certification body

Inspection body

Pegler Yorkshire Ltd

Sudopress

Product type

date

SC1013-16

mm

†

1002

RISE

DTI

## Basis for judgement/approval

Report: 120003790,120003791 and 120001607 from MPA NRW.

Report: 7P02666 from RISE. Report from KIWA dated 4:th October 2018.

## Comments

The fittings are approved in accordance with NKB Product Rules no. 12

"Mechanical couplings of metal for copper pipes for drinking water installations".

## Validity

Valid through 2024-09-01.

The validity of this approval expires when the characteristics included in this approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

Marcus Tillman

Stefan Coric

*This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.*

Type approval SC1013-16 | 2019-09-02

RISE Research Institutes of Sweden AB | Certification