



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NW-6305BO0205

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Hans Sasserath GmbH & Co. KG Mühlenstraße 62, D-41352 Korschenbroich
Distributor <i>Vertreiber</i>	Hans Sasserath GmbH & Co. KG Mühlenstraße 62, D-41352 Korschenbroich
Product Category <i>Produktart</i>	valves for drinking water: backflow preventer BA (6305)
Product Description <i>Produktbezeichnung</i>	backflow preventer BA with or without service ball valve
Model <i>Modell</i>	BA 66...
Test Reports <i>Prüfberichte</i>	supplement test: ST 014/19 from 25.09.2019 (TZW) type testing: ST 016/19+017/19+018/19 from 26.03.2020 (TZW) type testing: ST 019/17+020/17+021/17 from 17.12.2018 (TZW) UBA-Guideline: KA 0278/19 from 15.10.2019 (TZW) hygienic testing: MO 243/16 from 28.11.2016 (TZW)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 570-1 (01.03.2013) DIN EN 12729 (01.02.2003) UBA METALLE (21.11.2018) UBA ELASTOM (16.03.2016) UBA KTW (07.03.2016) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	26.06.2023 / 18-0533-WNR

70028-04-A-DE

15.06.2020 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
BA 6600	noise emission class: II pressure rating: PN 10 nominal diameter: DN 15	
BA 6600	noise emission class: II pressure rating: PN 10 nominal diameter: DN 20	
BA 6600	noise emission class: II pressure rating: PN 10 nominal diameter: DN 25	
BA 6600	noise emission class: II pressure rating: PN 10 nominal diameter: DN 32	
BA 6600	pressure rating: PN 10 nominal diameter: DN 40	
BA 6600	pressure rating: PN 10 nominal diameter: DN 50	
BA 6600	pressure rating: PN 10 nominal diameter: DN 65	
BA 6600	pressure rating: PN 10 nominal diameter: DN 80	
BA 6600	pressure rating: PN 10 nominal diameter: DN 100	
BA6610 in-line LF	noise emission class: I pressure rating: PN 10 nominal diameter: DN 15	
BA6610 in-line LF	noise emission class: I pressure rating: PN 10 nominal diameter: DN 20	
BA6610 in-line LF	noise emission class: I pressure rating: PN 10 nominal diameter: DN 25	
BA6610 in-line LF	noise emission class: I pressure rating: PN 10 nominal diameter: DN 32	
BA6610 in-line LF	pressure rating: PN 10 nominal diameter: DN 40	
BA6610 in-line LF	pressure rating: PN 10 nominal diameter: DN 50	

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. Registr.-Nr.	Component Bauteil (Produktart)	Model/Type Modell/Typ	Manufacturer Hersteller
NW-6312AS2269	plug-in non-return valve	OF, OD, OV, NF, NV, CV, SYR/OV25, NV25	NEOPERL GmbH

