

European Technical Assessment



English translation prepared by IETcc. Original version in Spanish language

General Part

Technical Assessment Body issuing the ETA designated according to Art. 29 of Regulation (EU) 305/2011:

Instituto de Ciencias de la Construcción Eduardo Torroja (IETcc)

Trade name of the construction product Product family to which the construction product belongs

Novipro ceiling anchor KS-X

Anchor made of galvanized steel for multiple use for non-structural applications in concrete.

Manufacturer

Manufacturing plants

This European Technical Assessment contains

This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of Dahl Sverige AB Bryggerivägen 9 168 67 Bromma. Sweden. website: <u>www.dahl.se</u>

Dahl Sverige AB plant 2

8 pages including 3 annexes which form an integral part of this assessment.

European Assessment Document 330474-00-0601 "Fasteners for use in concrete for redundant non-structural systems", edition May 2018

This European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission according to article 25 (3) of Regulation (EU) No 305/2011.

SPECIFIC PART

1. Technical description of the product

The Novipro ceiling anchor KS-X in diameter 6 is an anchor made of galvanized steel. The anchor is installed into a predrilled cylindrical hole and anchored by deformation-controlled expansion.

Product and product description is given in annex A.

2. Specification of the intended use in accordance with the applicable European Assessment Document.

The performances given in section 3 are only valid if the anchor is used in compliance with the specifications and conditions given in annex B.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the anchor of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a mean to choosing the right products in relation to the expected economically reasonable working life of the works.

3. Performance of the product and references to the methods used for its assessment

3.1 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire	Anchorages satisfy requirements for class A1
Essential characteristics under fire exposure	See annex C2

3.2 Safety in use (BWR 4)

Essential characteristic	Performance
Essential characteristics in concrete	See annex C2

4. Assessment and Verification of Constancy of Performances (hereinafter AVCP) system applied, with reference to its legal base

The applicable European legal act for the system of Assessment and Verification of Constancy of Performances (see annex V to Regulation (EU) No 305/2011) is 97/161/EC.

The system to be applied is 2+.

5. Technical details necessary for the implementation of the AVCP system, as provided for in the applicable European Assessment Document.

The technical details necessary for the implementation of the AVCP system are laid down in the quality plan deposited at Instituto de ciencias de la construcción Eduardo Torroja.



Instituto de ciencias de la construcción Eduardo Torroja CONSEJO SUPERIOR DE INVESTIGACIONES CIENTÍFICAS

C/ Serrano Galvache n.º 4. 28033 Madrid. Tel: (+34) 91 302 04 40 Fax. (+34) 91 302 07 00 www.ietcc.csic.es



On behalf of the Instituto de Ciencias de la Construcción Eduardo Torroja Madrid, 3rd of May 2022



Director IETcc - CSIC




Table A1: materials

Item	Designation	Material for KS-X
1	Anchor body	Carbon steel wire rod, galvanized \ge 5 µm ISO 4042 A2
2	Shank	Carbon steel wire rod, galvanized \ge 5 µm ISO 4042 A2

KS-X ceiling anchor

Product description

Installed condition and materials

Annex A1

Specifications of intended use

Anchorages subjected to:

- Static or quasi static loads for redundant non-structural systems.
- Use for anchorages with requirements related to resistance of fire.
- The anchor may only be used if in the design and installation specifications for the fixture the excessive slip or failure of one anchor will not result in a significant violation of the requirements on the fixture in the serviceability and ultimate state.

Base materials:

- Reinforced or unreinforced normal weight concrete without fibres according to EN 206-1:2013+A1:2016.
- Strength classes C20/25 to C50/60 according to EN 206-1:2013+A1:2016.
- Cracked or uncracked concrete

Use conditions (environmental conditions):

• Anchorages subjected to dry internal conditions.

Design:

- Anchorages are designed under the responsibility of an engineer experienced in anchorages and concrete.
- Verifiable calculation rules and drawings are prepared taking into account of the loads to be anchored. The position of the anchor is indicated on the design drawings (e.g. position of the anchor relative to reinforcement or to supports, etc.).
- Anchorages under static or quasi-static actions are designed for design method C in accordance with EN 1992-4:2018
- Anchorages under fire exposure are designed in accordance to EN 1992-4:2018. It must be ensured that local spalling of the concrete cover does not occur.

Installation:

- Hole drilling by rotary plus hammer mode.
- Anchor installation carried out by appropriately qualified personal and under the supervision of the person responsible for technical matters of the site.
- Anchor expansion by impact on the shank. The anchor is properly set, if no further driving by impact is possible and the excess of the shank is at maximum 2,5 mm.
- The anchor may only be set once.

KS-X ceiling anchor		
Intended use	Annex B1	
Specifications		

Table C1: Installation parameters for KS-X ceiling anchor

Installation parameters		Performances			
		KS-X 6 x 40	KS-X 6 x 70		
do	Nominal diameter of drill bit:	[mm]	6		
df	Fixture clearance hole diameter:	[mm]	7		
h _{min}	Minimum thickness of concrete member:	[mm]	80		
h₁	Depth of drilled hole ≥	[mm]	40		
h _{ef}	Effective anchorage depth ≥	[mm]	32		
t _{fix}	Thickness of fixture:	[mm]	0 - 5 0 - 35		
Smin	Minimum spacing:	[mm]	200		
Cmin	Minimum edge distance:	[mm]	150		

Installation process



KS-X ceiling anchor	
Performances	Annex C1
Installation parameters and installation procedure	

Table C2: Essential characteristics in concrete to loads of design method C according to EN 1992-4 for KS-X ceiling anchor

	aracteristic values of resistance to loads of design		Perforr KS-X 6 x 40	nances KS-X 6 x 70	
Any load direction					
F ⁰ Rk	Characteristic resistance in C20/25 to C50/60 concrete:	[kN]	3,0		
γ_{inst}	Installation safety factor: 1)	[-]	1,2		
Shear loads: steel failure with lever arm					
M ⁰ Rk,s	Characteristic bending moment	[Nm]	3,68		
γMs	Partial safety factor: 1)	[-]	1,25		

¹⁾ in absence of other national regulations

Table C3: Essential characteristics under fire exposure in concrete in any load direction according to EN 1992-4 for KS-X ceiling anchor

Characteristic resistance under fire exposure in concrete C20/25 to C50/60 in any load direction		Performances		
		KS-X 6 x 40	KS-X 6 x 70	
R30	Characteristic resistance F ⁰ _{Rk,fi,30} ¹⁾	[kN]	0,4	41
R60	Characteristic resistance F ⁰ _{Rk,fi,60} ¹⁾	[kN]	0,30	
R90	Characteristic resistance F ⁰ _{Rk,fi,90} ¹⁾	[kN]	0,19	
R120	Characteristic resistance F ⁰ _{Rk,fi,120} ¹⁾	[kN]	0,14	
R30 to	Minimum spacing Smin,fi	[mm]	20	00
R120	Minimum edge distance c _{min,fi} ²⁾	[mm]	15	50

 $^{1)}$ in absence of other national regulations the partial safety factor for resistance under fire exposure $\gamma_{M,fi}$

 =1.0 is recommended.
²⁾ If fire attack is from more than one side, the design method may be taken if edge distance of the anchor is $c \ge 300$

KS-X ceiling anchor

Performances Essential characteristics in concrete Essential characteristics under fire exposure

Annex C2