



**CERT**

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DW-8511BL0157**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	Georg Fischer Fittings GmbH Mariazeller Straße 75, A-3160 Traisen
<b>Distributor</b> <i>Vertreiber</i>	Georg Fischer Fittings GmbH Mariazeller Straße 75, A-3160 Traisen
<b>Product Category</b> <i>Produktart</i>	installation systems and system joints: pipe joint for pipes in drinking water installation systems (8511)
<b>Product Description</b> <i>Produktbezeichnung</i>	clamp fitting type M-MM made of zinc plated malleable cast iron for zinc plated steel pipes, for cold water
<b>Model</b> <i>Modell</i>	PRIMOFIT
<b>Test Reports</b> <i>Prüfberichte</i>	laboratory control test: 120000517-19 from 30.01.2020 (MPM) supplement test: 411.334-2k from 10.06.2014 (MPM) mechanical test: 120004242 from 27.11.2013 (MPM) UBA-Guideline: KA 0291/16 from 04.10.2016 (TZW) hygienic testing: MO 081/17 from 10.08.2017 (TZW) KTW testing: K-255053-15-Ko/st from 24.03.2015 (WHY) hygienic testing: W-300428e-18-SI/Krü from 11.07.2018 (WHY)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DVGW W 534 (01.05.2004) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)
<b>Date of Expiry / File No.</b> <i>Ablaufdatum / Aktenzeichen</i>	11.04.2025 / 20-0104-WNV

70228-04-A-DE

17.03.2020 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-05

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
PRIMOFIT	nominal diameter: 3/8"	
PRIMOFIT	nominal diameter: 1/2 "	
PRIMOFIT	nominal diameter: 3/4 "	
PRIMOFIT	nominal diameter: 1 "	
PRIMOFIT	nominal diameter: 1 1/4 "	
PRIMOFIT	nominal diameter: 1 1/2 "	
PRIMOFIT	nominal diameter: 2 "	
PRIMOFIT	nominal diameter: 2 1/2 "	
PRIMOFIT	nominal diameter: 3 "	
PRIMOFIT	nominal diameter: 4"	

**certified Components*****zertifizierte Bauteile / Werkstoffe***

Registr. No. <i>Registr.-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
NW-5253BT0306	sealing material for drinking water installations	TIMO 3-70/TIMO 3-70	Tecnogomma International S.p.A.
NW-5213CN0235	Elastomer sealant for gas and water supply mains and pipelines	TEC N41-70/TEC N41-70	Tecnogomma International S.p.A.

**Hints of Utilization / Remarks*****Verwendungshinweise / Bemerkungen***

Only to use for cold water.

The testing was made with DVGW-certified zinc-coated steel pipes.

